

ELDES SNC

KFA310 Relay Test Set



ELDES**KFA310 Relay Test Set**

Item	KFA310	Remark
Voltage	4x300V	
Accuracy	<±0.02%rd+0.03%rg	
Voltage Power	22.5VA Max	
Current range	0-10A, LN 0-20A, LL-N 0-30A, LLL-N	Optional upgrade current range to 3x0~20A LN Max 0~50A LLL-N
Current Power	130VA Max	
Phase	0° ~360°	
Frequency	10-1000Hz	
Harmonic	2~60th	
GPS, IRIG-B	Support	
Binary IN/OUT	4 Binary IN/OUT	
USB Port	1*USB3.0	
WIFI, Blue Tooth	Support	
Low-Level Output	Support	
Energy Meter	Support	

Total Function

Special Points

B5 paper size, **built-in battery design**, for on-site maintenance and testing of **non-electric environment**, protection relay testing, secondary circuit inspect and secondary voltage and current testing.




Technical Benifit

- Device Size: IPAD size, aluminum alloy case, Very small and light.
- Device Weight: 3.7kg ,Beautiful and light, easy to carry and use.
- Operational performance:high-performance FPGA, 32-bit ARM microprocessor 1000MHz, smooth operation, 7.0-inch LED capacitive touch screen, full touch operation, mobile phone operation habits, display light transmission, non-reflective contrast, clear display for outdoor
- Equipment self-protection function: voltage output short-circuit, current output open-circuit, temperature overheat protection.



KFA310 – Introduction

Hardware design Diagram





AC Voltage Outputs		
Output Range & Power	4×300 V ac (L-N)	22.5 VA max each@300V
		21 VA max each@200V
		12.5 VA max each@100V
		7 VA max each@63.5V
		6.65 VA max each@57.7V
		1.1 VA max each@10V
Accuracy	<0.015%Rd+0.005%Rg Typ. <0.02%Rd+0.03%Rg Guar.	
Resolution	0.001V	
DC Offset	<5mV Typ. <60mV Guar	
Distortion	<0.05%Typ. / <0.1% Guar.	
Ascends/Descent response	<100us	
DC Voltage Outputs		
Source Channels	4	
DC voltage output range	0~300 V (L-N)	
DC voltage output power	22.5W Max	
DC voltage accuracy	<0.03%Rd+0.01Rg Typ. <0.04%Rd+0.06Rg Guar.	
Ascends/Descent response	<100us	
Resolution	1mV	



AC current outputs	
Source Channels	3
AC current output range	0~10A, L-N / (Can be optional as 0~20A)
	0~20A, LL-N / (Can be optional as 0~40A)
	0~30A, LLL-N / (Can be optional as 0~50A)
AC current output power (Max)	75VA Max for 10A L-N 130VA Max for 20A L-N/LL-N
AC current output accuracy	<0.015%Rd+0.01%Rg Typ. <0.02%Rd+0.03%Rg Guar.
DC Offset	<1mA Typ. <2mA Guar
Distortion	<0.05%Typ. / <0.1% Guar.
Ascends/Descent response	<100us
Resolution	1mA
DC current outputs	
Source Channels	1
DC current output range	0~10A, L-N
DC current output power	138W
DC current accuracy	<0.03%Rd+0.01Rg Typ. <0.04%Rd+0.06Rg Guar.
Resolution	1mA

Hardware Introduce

Binary input and time accuracy	
Binary input logarithm	4 pairs
Trigger mode	Try/Wet contact
Input voltage range	0 V~300Vdc
Timing accuracy	< ±1ms @ 0.001~1s, < ±0.1% @>1s
Timing resolution	36us
Max time limit	infinity

Binary output(Relay Contacts)	
Binary output pairs	2pairs(DO-1 and DO-2)
Type	Potential free relay contacts, software controlled
Break capacity AC	Vmax: 380V (AC) / Imax: 8A/ Pmax: 2000VA
Break capacity DC	Vmax: 240V (DC) / Imax: 5A/ Pmax: 150W
Responce time	≤ 10ms
Binary output(Fast eSSR)	
Binary output pairs	2pairs(DO-3 and DO-4)
Circuit Breaker Simulate	Can be define as Open or Close status
Break capacity AC	Vmax: 250V (AC) / Imax: 0.5A
Break capacity DC	Vmax: 250V (DC) / Imax: 0.5A
Responce time	<100us
Contact performance	Open the dry contact output using opto-coupler relay, the max on-resistance is ≤6Ω (Typically ≤1Ω), and the shut-off withstand voltage is ≥DC300V




Hardware Introduce

GPS Port
Can connect to external antenna, for end-to-end test on line differential or other synchronize testing.
When GPS synchronize works, LED beside port will light up.

Serial port
For debugging

Low level outputs	
Number of outputs	8
Setting range	0~8Vrms
Max. output current	Rating 2mA, 10mA transient max.
Accuracy	(0.01~0.8 Vrms) : <0.05% Typ. / <0.1% Guar. (0.8~8 Vrms) : <0.02% Typ. / <0.05% Guar.
Resolution	250 μ V
Distortion (THD+N)	< 0.05% Typ. / <0.1% Guar.
Connection interface	Phoenix terminal



IRIG-B Synchronization Port	
Port define	Use for IRIG-B synchronize, or can be set as time clock source.
Time accuracy	5us

Energy Pulse Port	
Sensor Usage	Mechanical meters / Electronic meters
Sensor Output	High lever:>4.5V, Low level:<0.2V
Pulse Input	1 pulse input port, 5Vdc high level valid only.
Pulse Range	500kHz pulse input Max.
Pulse Output	1 Transistor output, Open-collector, 5Vdc/5mA

USB
USB Port 3.0, use for report upload and software update.

Communication	
RJ45 (Reserve)	Ethernet port, TCP/IP protocol, use for communication with PC for operation control

Ext	
Data bus	Use for hardware function extension, such as Binary input/output numbers, external measurement, LVPT, LPCT testing.



Power switch	
Power on or power off device	
Aux. DC	
Use for power supply of under test device.	
Output range	12~350V
Output power	40W max
Accuracy	<1%

Grounding port	
Use for grounding	
AC/DC Charger	
Input	100~240Vac, 50/60Hz, Max2.5A
Output	33.6Vdc, 5.0A (168W)




Dimensions(W x D x H):288x185x95 (mm)

3.7Kg



Extremely light



Distribution test




Oil and Gas Platforms



Substations



Industry



Photovoltaic plants



Rail and Metro



Wind Farm

Standard source




Because the output signal of KFA310 has high precision and high stability, it can be used as a 3-phase standard and a calibration signal source for instruments.

We KFA310 Support two sets of software which can switch by user, in different testing environment of substation and distribution.

Substation Test Software interface



Distribution Test Software interface



Substation Test Software interface

AC test module interface

2022-09-08 10:52:34

UA:	57.735 V	0.000 °	50.000 Hz	Parameter Setting
UB:	57.735 V	240.000 °	50.000 Hz	
UC:	57.735 V	120.000 °	50.000 Hz	
IA:	1.000 A	0.000 °	50.000 Hz	
IB:	1.000 A	240.000 °	50.000 Hz	
IC:	1.000 A	120.000 °	50.000 Hz	

Trip Value Trip Time Return.Coeff

Start DI:1 2 DO:1 2 Calc Report

Fault-Calc

Fault Parameter		Short-Circuit Impedance	
Mode	Const I	Fault-I	1.000 A
F-Type	A-N	Load-I	0.000 A
CT Dir.	Line	Load-θ	0.000 °
PT Dir.	Line	Grounding Factor	
Fault Dir.	Forward	Mode	KL
		KL Range	0.670
		KL Angle	0.000 °

|Z| 0.000 Ω R 0.000 Ω
θ 75.000 ° X 0.000 Ω

OK Cancel

Substation Test Software interface

Distance module interface

2022-09-08 10:57:14 Distance

Parameter	Setting
Z	0.000 Ω
θ	75.000 °
Fault	A-N
Fault Dir.	Forward
	Time
	1.000 s

UA	0.000V	0.000°
UB	57.735V	240.000°
UC	57.735V	120.000°
IA	1.000A	0.000°
IB	0.000A	0.000°
IC	0.000A	0.000°

Impedance Factor	
0.70	0.95
1.05	1.20

Test Result

Fault	Fault Dir.	Z	Zθ	T.nom	Dev	Trip Time	DI	Result

Start DI:1 o— 2 ♂ DO:1 ♂ 2 ♂ Report

2022-09-08 10:57:29 Distance

Parameter	Setting
Mode	Const I
CT Dir.	Line
PT Dir.	Line
T.Prefault	3.000 s

Fault-I	1.000 A
Load-I	0.000 A
Load-θ	0.000 °

Grounding	KL
KL Range	0.670
KL Angle	0.000 °

T.Interval	1.000 s
------------	---------

Start DI:1 o— 2 ♂ DO:1 ♂ 2 ♂ Report

Substation Test Software interface

Ramping module interface

2022-09-08 10:58:05 Ramping

Voltage		Current		Parameter Setting			
UA:	0.000 V	0.000 °	50.000 Hz	Start:	0.000 V	End:	57.735 V
UB:	57.735 V	240.000 °	50.000 Hz	Step:	1.000 V	Time:	1.000 s
UC:	57.735 V	120.000 °	50.000 Hz	Variable:	UA	TestItem:	Amplitude
				Mode:	Phase	Function:	50
				T.Prefault:	1.000 s	Output Once	
				T.Interval:	0.200 s	Add	Delete

Test Result

Variable	Function	T.nom	Dev	Trip Time	DI	Result

Buttons: Start, DI:1 ♂ 2 ♂, DO:1 ♂ 2 ♂, Report

Harmonic test module interface

2022-09-08 10:57:43 Harmonic

Setting			
Order:	1	[1/5]	+
UA:	57.735 V	0.000 °	-
UB:	57.735 V	240.000 °	From-to
UC:	57.735 V	120.000 °	
IA:	1.000 A	0.000 °	
IB:	1.000 A	240.000 °	
IC:	1.000 A	120.000 °	
Auto	1.000 s	Order:	1
Variable:	UA	TestItem:	Range
THD:	Amplitude	Percentage	
T.nom:	1.000 s	Dev:	0.100 s

Test Result

Variable	T.nom	Dev	Trip Time	DI	Result
UA	1.000s	0.100s			NoTest

Buttons: Start, DI:1 ♂ 2 ♂, DO:1 ♂ 2 ♂, Report

Substation Test Software interface

Overcurrent module interface

2022-09-08 10:58:25 Overcurrent

Parameter		Setting						
Time Overcurrent(50)		Inst. Overcurrent(51)						
Pick-up:	1.000 A	Pick-up:	1.000 A					
Time Dial:	1.000 s	Time Dial:	1.000					
Curve:	IEC-NI	Function:	50					
FaultType:	A-N	I-test:	0.000 A					
		Add						
		FaultType:	Multi					
<input type="checkbox"/> Test Result								
FaultType	ABS	Function	T.nom	T.min	T.max	Trip Time	DI	Result

Start DI:1 o— 2 ♂ DO:1 ♂ 2 ♂ **Report**

2022-09-08 10:58:49 Overcurrent

Parameter		Setting						
Current Tol:		5.000	%					
Time Tol:		5.000	%					
Max Fault Time:		200.000	s					
<input type="checkbox"/>	T.Prefault:	0.500	s					
<input type="checkbox"/>	Output Once							
<input type="checkbox"/>	T.Interval:	0.200	s					
<input type="checkbox"/>	OC Directional							
	V.Fault L-N:	30.000	V					
	Current Angle:	-60.000	°					
<input type="checkbox"/> Test Result								
FaultType	ABS	Function	T.nom	T.min	T.max	Trip Time	DI	Result

Start DI:1 o— 2 ♂ DO:1 ♂ 2 ♂ **Report**

Substation Test Software interface

Overcurrent module interface



Substation Test Software interface

State Sequencer module interface

2022-09-08 10:53:21 Sequence

State [1 / 3]		Start	Stop	Test Result	Assessment
Voltage Current					
UA:	57.735 V	0.000 °	50.000 Hz		
UB:	57.735 V	240.000 °	50.000 Hz		
UC:	57.735 V	120.000 °	50.000 Hz		
Trip: Time Angle: Phase					
Time: 1.000 s					
Logic: And Or					
DI: <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2					
DO: ♂ 1 ♀ 2					
Calc					

Test Result Assessment

State	DI 1	DI 2
1	NoTest	NoTest
2	NoTest	NoTest
3	NoTest	NoTest

Start DI:1♂ 2♂ DO:1♂ 2♂ Report

2022-09-08 10:53:45 Sequence

State [1 / 3]		Start	Stop	Test Result	Assessment	Add	Delete	Clear
Voltage Current								
IA:	1.000 A	0.000 °	50.000 Hz					
IB:	1.000 A	240.000 °	50.000 Hz					
IC:	1.000 A	120.000 °	50.000 Hz					
Trip: Time Angle: Phase								
Time: 1.000 s								
Logic: And Or								
DI: <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2								
DO: ♂ 1 ♀ 2								
Calc								

Start DI:1♂ 2♂ DO:1♂ 2♂ Report

Substation Test Software interface

Remote module interface

2022-09-08 11:08:43 Remote

Storm Test Resolution Test

Width: ms

Count:

Enable-DI: 1 2

Start DI:1 2 DO:1 2 Clear SOE

2022-09-08 11:09:18 Remote

Storm Test Resolution Test

DO1 Width: ms

DO2 Width: ms

Resolution: ms

Start DI:1 2 DO:1 2 Clear SOE

Distribution Test Software interface

MultiTest module interface

2022-09-08 11:12:21

Multi Test

UA:	57.735 V	0.000 °	50.000 Hz
UB:	57.735 V	240.000 °	50.000 Hz
UC:	57.735 V	120.000 °	50.000 Hz
IA:	1.000 A	0.000 °	50.000 Hz
IB:	1.000 A	240.000 °	50.000 Hz
IC:	1.000 A	120.000 °	50.000 Hz

U	100%	+10%	-10%
I	100%	+10%	-10%

Start DI:1 2 DO:1 2

Clear SOE

SOE List:
HH:mm:ss:ff SOE event info

Fault Test module interface

2022-09-08 11:12:59

Fault Test

Norm(U,F):	57.735 V	50.000 Hz
Load-I:	1.000 A	0.000 °
Fault-U:	30.000 V	
Fault-I:	2.000 A	0.000 °
Max Time:	10.000 s	
Pre-Fault:	10.000 s	
Fault-DO:	<input checked="" type="checkbox"/> 1	<input checked="" type="checkbox"/> 2

Trip:

Start DI:1 2 DO:1 2

Clear SOE

SOE List:
HH:mm:ss:ff SOE event info

Distribution Test Software interface

State Sequencer module interface

2022-09-08 11:12:42 Sequence

SOE List:
HH:mm:ss:ff SOE event info

UA:	57.735 V	0.000 °	50.000 Hz
UB:	57.735 V	240.000 °	50.000 Hz
UC:	57.735 V	120.000 °	50.000 Hz
IA:	1.000 A	0.000 °	50.000 Hz
IB:	1.000 A	240.000 °	50.000 Hz
IC:	1.000 A	120.000 °	50.000 Hz

DO: 1 2 Time: 1.000 s

Trip: No Action No Action

Start DI:1 2 DO:1 2 Clear SOE

2022-09-08 10:53:45 Sequence

Voltage Current

IA:	1.000 A	0.000 °	50.000 Hz
IB:	1.000 A	240.000 °	50.000 Hz
IC:	1.000 A	120.000 °	50.000 Hz

Trip: Time Angle: Phase Time: 1.000 s Logic: And Or DI: 1 2 DO: 1 2 Calc

Add Delete Clear

Test Result Assessment Start Stop T.nom Dev Act Time Result

Start DI:1 2 DO:1 2 Report

Distribution Test Software interface

Remote module interface

2022-09-08 11:13:32 Remote

Storm Test Resolution Test

DO1 Width: ms

DO2 Width: ms

Resolution: ms

SOE List:
HH:mm:ss:ff SOE event info

Start DI:1 2 DO:1 2 Clear SOE

2022-09-08 11:13:16 Remote

Storm Test Resolution Test

Width: ms

Count:

Enable-DI: 1 2

Start DI:1 2 DO:1 2 Clear SOE

Distribution Test Software interface**System Setting module interface**

2022-09-08 11:00:47 System

Norm.Volt:	57.735 V	Norm.Curr:	1.000 A
Norm.Freq:	50.000 Hz	Deglitch Time:	0.015 s
System Time: 2022-09-08 11:00:50 <input type="button" value="Set"/>			
Theme:	<input checked="" type="radio"/> Default	<input type="radio"/> Blue	
Language:	<input type="radio"/> Chinese	<input checked="" type="radio"/> English	<input type="radio"/> Portuguese
Device Type:	KFA		
Serial Number:	0000		
Software Version:	1.3.0002		
Firmware Version:	0.0.0000		

2022-09-08 11:04:39 Hardware

Device Type:	KFA	Temp.Off:	70 °C
Serial Number:	0000	Temp.On:	50 °C
Max Voltage:	265.000 V	Volt.Range:	26.500 V
Max Current:	10.000 A	Curr.Range:	1.000 A
Voltage/Current Output Phase: <input checked="" type="checkbox"/> 3 <input type="checkbox"/> 4			